Lake Murray – Harbison 115 kV: Re-terminate Saluda Hydro – Harbison and rebuild SPDC

Project ID

0203C-D

Project Description

Re-terminate the Saluda Hydro – Harbison 115 kV line to Lake Murray substation in preparation for the SPDC rebuild of the Lake Murray – Harbison 115 kV which will add an additional line to create Saluda Hydro – Denny Terrace 115 kV line.

Project Need

System growth in the Irmo, Harbison, Piney Woods Road, and Kingswood areas requires additional 115 kV capacity and transmission path to increase reliability.

Project Status

In Progress

Planned In-Service Date

8/1/22

Previous	2022	2023	2024	2025	2026	Total*
\$9,396,116	\$90,000	\$0	\$0	\$0	\$0	\$9,486,116

^{*}Total Estimated Amount to be applied to 2022 Rate Base Calculation

Bluffton - Santee 115 kV Tie Line Construct

Project ID

7101A

Project Description

Construct a new 115 kV tie line from DESC Bluffton substation to SCPSA Bluffton substation. Total line length approximately 1.5 miles.

Project Need

This line is needed to reduce outage durations for planned outages and emergency situations for DESC's Bluffton, Hardeeville and Pritchardville substations.

Project Status

In Progress

Planned In-Service Date

12/31/2022

Previous	2022	2023	2024	2025	2026	Total*
\$2,471,155	\$175,000	\$0	\$0	\$0	\$0	\$2,646,155

^{*}Total Estimated Amount to be applied to 2022 Rate Base Calculation

Queensboro - Ft Johnson 115 kV & Queensboro-Bayfront 115kV (**Queensboro-James Island Sect**)

Project ID

6807 B

Project Description

Replace the Queensboro – Ft Johnson 115 kV Line as the line has reached the end of its usable life.

Project Need

This project is required due to address end of life issues with current line.

Project Status

In Progress

Planned In-Service Date

12/31/23

Previous	2022	2023	2024	2025	2026	Total*
\$2,880,295	\$1,000,000	\$0	\$0	\$0	\$0	\$3,880,295

^{*}Total Estimated Amount applied to 2022 Rate Base Calculation

Edenwood Sub: Replace Switch house

Project ID

7990 A

Project Description

Replace switch house and associated equipment at Edenwood Substation.

Project Need

Replace end of life components and allow for future expansion.

Project Status

In-Progress

Planned In-Service Date

7/31/2022

Previous	2022	2023	2024	2025	2026	Total*
\$3,671,247	\$200,000	\$0	\$0	\$0	\$0	\$3,871,247

^{*}Total Estimated Amount applied to 2022 Rate Base Calculation

Lake Murray - Gilbert 115 kV Line

Project ID

6807 C-E

Project Description

Rebuild the existing Lake Murray - Gilbert 115 kV Line, adding an additional circuit between Lexington Junction and Lexington Transmission and provisions for a future circuit to be pulled between Lexington Westside and Gilbert.

Project Need

This project is required to meet NERC TPL standards and DESC's Internal Planning Criteria and allow for future load growth and system expansion.

Project Status

In Progress

Planned In-Service Date

12/31/22

Previous	2022	2023	2024	2025	2026	Total*
\$2,332,714	\$2,300,000	\$0	\$0	\$0	\$0	\$4,632,714

^{*}Total Estimated Amount applied to 2022 Rate Base Calculation

Burton-Yemassee 115 kV #2 Line Rebuild as Double Circuit

Project ID

1268A-J

Project Description

Burton-Yemassee 115 kV Line #2: Rebuild 115 kV SPDC using B795 ACSR (line length 21.24 miles).

Project Need

System load growth in the Burton area requires additional transmission capacity from the Yemassee 230/115 kV substation and added transmission path to increase reliability.

Project Status

In Progress

Planned In-Service Date

12/31/2023

Previous	2022	2023	2024	2025	2026	Total*
\$48,192,850	\$2,085,000	\$1,600,000	\$0	\$0	\$0	\$51,877,850

^{*}Total Estimated Amount to be applied to 2023 Rate Base Calculation

Ward- Stevens Creek 115 kV: Ward - Trenton Section Rebuild

Project ID

6807 H

Project Description

Rebuild the existing 115 kV line between Ward and Trenton Transmission as 1272 ACSR conductor.

Project Need

This project is required to meet NERC TPL standards and DESC's Internal Planning Criteria and allow for future load growth and system expansion.

Project Status

In Progress

Planned In-Service Date

12/31/22

Previous	2022	2023	2024	2025	2026	Total*
\$5,563,694	\$2,000,000	\$0	\$0	\$0	\$0	\$7,563,694

^{*}Total Estimated Amount applied to 2022 Rate Base Calculation

Union Pier 115-13.8 kV Sub: Tap

Project ID

0167C-D

Project Description

Installing a 115 kV Tap to feed the future Union Pier 115 kV Sub.

Project Need

This project is needed to for load growth in the Charleston area.

Project Status

Planned

Planned In-Service Date

12/31/25

Previous	2022	2023	2024	2025	2026	Total*
\$0	\$0	\$0	\$300,000	\$4,200,000	\$0	\$4,500,000

^{*}Total Estimated Amount applied to 2025 Rate Base Calculation

Okatie 230-115kV Substation, Jasper - Yemassee 230kV #1 Fold-in

Project ID

0139 M,N

Project Description

Construct the new Lakeside 230 kV substation near the Okatie 115 kV substation, add a 230/115 transformer and fold the Jasper – Yemassee 230 kV #1 line into Lakeside and construct a 115 kV line from Lakeside to Okatie 115 kV..

Project Need

This project is needed to improve system performance and to meet NERC TPL and internal DESC Planning Criteria for reliability.

Project Status

In Progress

Planned In-Service Date

12/31/2023

Previous	2022	2023	2024	2025	2026	Total*
\$285,213	\$3,560,000	\$3,510,000	\$0	\$0	\$0	\$7,355,213

^{*}Total Estimated Amount applied to 2023 Rate Base Calculation

Cainhoy - Hamlin 115kV: Rebuild Line and Cainhoy - Hamlin 115 kV #2: Construct New 115 kV Line

Project ID

6341 A-F

Project Description

Upgrade the 954 ACSR portion of the Cainhoy – Hamlin 115 kV line to B795 ACSR conductor, construct a new Cainhoy – Hamlin 115 kV #2 line, add terminals to Cainhoy and Hamlin sub to accommodate upgrades.

Project Need

This project is required due to load growth in the Mount Pleasant area and to meet NERC TPL and internal DESC Planning criteria.

Project Status

Planned

Planned In-Service Date

12/01/24

Previous	2022	2023	2024	2025	2026	Total*
\$4,283	\$900,000	\$6,690,000	\$14,210,000	\$2,250,000	\$0	\$24,024,283

^{*}Total Estimated Amount applied to 2024 Rate Base Calculation

Church Creek-Queensboro 115kV: Stono River Crossing

Project ID

6808 B

Project Description

Rebuild the existing Stono River crossing section of the Church Creek-Queensboro 115 kV line, replacing wooden H-frame structures with Self Supporting Steel SPDC Structures.

Project Need

This project is required to address end of life and reliability issues on these lines.

Project Status

Planned

Planned In-Service Date

12/31/24

Previous	2022	2023	2024	2025	2026	Total*
\$5,981,480	\$0	\$7,840,000	\$0	\$0	\$0	\$13,821,480

^{*}Total Estimated Amount applied to 2022 Rate Base Calculation

Queensboro - Johns Island 115 kV Tie: Rebuild River and Marsh Crossing

Project ID

6808 G

Project Description

Rebuild the existing Stono River crossing section of the Church Creek- Johns Island (SCPSA) 115 kV line, replacing wooden H-frame structures with Self Supporting Steel SPDC Structures.

Project Need

This project is required to address end of life and reliability issues on these lines.

Project Status

Planned

Planned In-Service Date

12/31/22

Previous	2022	2023	2024	2025	2026	Total*
\$2,742,504	\$6.800.000	\$0	\$0	\$0	\$0	\$9,542,504

^{*}Total Estimated Amount applied to 2022 Rate Base Calculation

Denny Terrace Sub: Replace Switch house

Project ID

7990 B

Project Description

Replace switch house and associated equipment at Denny Terrace Substation.

Project Need

Replace end of life components and allow for future expansion.

Project Status

In-Progress

Planned In-Service Date

6/1/2023

Previous	2022	2023	2024	2025	2026	Total*
\$1,702,000	\$2,100,000	\$465,000	\$0	\$0	\$0	\$4,267,631

^{*}Total Estimated Amount applied to 2023 Rate Base Calculation

Denny Terrace-Crafts Farrow & Denny Terrace-Dentsville Line #1 115kV Rebuild

Project ID

6808 I

Project Description

Replace wooden structures with Self Supporting Steel Structures.

Project Need

This project is required to address end of life and reliability issues on these lines.

Project Status

In Progress

Planned In-Service Date

12/31/22

Previous	2022	2023	2024	2025	2026	Total*
\$2,905,886	\$3,200,000	\$0	\$0	\$0	\$0	\$6,105,886

^{*}Total Estimated Amount applied to 2022 Rate Base Calculation

Eastover - Square D 115kV: Rebuild

Project ID

6808 J

Project Description

Replace wooden H-Frame structures with Self Supporting Steel Structures and restring with 1272 ACSR conductor.

Project Need

This project is required to address end of life and reliability issues on these lines.

Project Status

In Progress

Planned In-Service Date

10/01/23

Previous	2022	2023	2024	2025	2026	Total*
\$2,108,448	\$2,000,000	\$2,900,000	\$0	\$0	\$0	\$7,008,448

^{*}Total Estimated Amount applied to 2023 Rate Base Calculation

Burton-St Helena 115kV: Rebuild Burton-Frogmore Transmission Section

Project ID

6808 K

Project Description

Replace wooden structures with Self Supporting Steel Structures and restring with 1272 ACSR conductor for the Burton – Frogmore Transmission section.

Project Need

This project is required to address end of life and reliability issues on these lines.

Project Status

In Progress

Planned In-Service Date

12/31/23

Previous	2022	2023	2024	2025	2026	Total*
\$3,472,743	\$0	\$5,400,000	\$0	\$0	\$0	\$8,872,743

^{*}Total Estimated Amount applied to 2023

Burton-St Helena 115kV: Frogmore Distribution - St Helena

Project ID

6808 L

Project Description

Replace wooden structures with Self Supporting Steel Structures and restring with 477 ACSR for the Frogmore Distribution Tap – St. Helena section.

Project Need

This project is required to address end of life and reliability issues on these lines.

Project Status

In Progress

Planned In-Service Date

12/31/24

Previous	2022	2023	2024	2025	2026	Total*
\$0	\$350,000	\$150,000	\$8,625,000	\$0	\$0	\$9,125,000

^{*}Total Estimated Amount applied to 2024 Rate Base Calculations

VCS1-Denny Terrace 230kV & VCS1-Pineland 230kV: Rebuild Double Circuit Section and Single Circuit Sections

Project ID

6808 M,N,O

Project Description

Replace wooden H-Frame structures with Self Supporting Steel Structures and restring with standard 1272 ACSR conductor.

Project Need

This project is required to address end of life and reliability issues on these lines.

Project Status

Planned

Planned In-Service Date

12/31/23

Previous	2022	2023	2024	2025	2026	Total
\$11,601,170	\$3,400,000	\$8,000,000	\$0	\$0	\$0	\$23,001,170

^{*}Total Estimated Amount applied to the 2023 Rate Base Calculations

Wateree-Hopkins 230kV Line #1: Rebuild

Project ID

6808 P

Project Description

Replace wooden H-Frame structures with Self Supporting Steel Structures and restring with 1272 ACSR conductor.

Project Need

This project is required to address end of life and reliability issues on these lines.

Project Status

Planned

Planned In-Service Date

12/31/26

Previous	2022	2023	2024	2025	2026	Total*
\$0	\$0	\$0	\$0	\$5,200,000	\$8,000,000	\$13,200,000

^{*}Total Estimated Amount applied to 2026 Rate Base Calculation

Wateree-Hopkins 230kV Line #2: Rebuild

Project ID

6808 Q

Project Description

Replace wooden H-Frame structures with Self Supporting Steel Structures and restring with 1272 ACSR conductor.

Project Need

This project is required to address end of life and reliability issues on these lines.

Project Status

In Progress

Planned In-Service Date

12/31/23

Previous	2022	2023	2024	2025	2026	Total*
\$3,54,612	\$950,000	\$6,000,000	\$0	\$0	\$0	\$10,490,612

^{*}Total Estimated Amount applied to 2023 Rate Base Calculation

Wateree-Killian 230kV: Rebuild

Project ID

6808 R

Project Description

Replace wooden H-Frame structures with Self Supporting Steel Structures .

Project Need

This project is required to address end of life and reliability issues on these lines.

Project Status

Planned

Planned In-Service Date

12/31/26

Previous	2022	2023	2024	2025	2026	Total*
\$0	\$550,000	\$350,000	\$25,500,000	\$24,500,000	\$0	\$50,900,000

^{*}Total Estimated Amount applied to 2025 Rate Base Calculation

Okatie-Bluffton 115kV: Rebuild

Project ID

6808 S

Project Description

Replace wooden H-Frame structures with Self Supporting Steel Structures and upgrade conductor to standard 1272 ACSR.

Project Need

This project is required to address end of life and reliability issues on these lines.

Project Status

Planned

Planned In-Service Date

12/31/24

Previous	2022	2023	2024	2025	2026	Total*
\$1,329	\$100,000	\$17.000.000	\$25,000,000	\$0	\$0	\$42,101,329

^{*}Total Estimated Amount applied to 2023 Rate Base Calculation

Hopkins-CIP 230kV: Rebuild

Project ID

6808 U

Project Description

Replace wooden H-Frame structures with Self Supporting Steel Structures.

Project Need

This project is required to address end of life and reliability issues on these lines.

Project Status

Planned

Planned In-Service Date

12/31/24

Previous	2022	2023	2024	2025	2026	Total*
\$0	\$300,000	\$850,000	\$1,50,000	\$0	\$0	\$2,650,000

^{*}Total Estimated Amount applied to 2024 Rate Base Calculation

Faber Place-Bayfront 115kV: Rebuild North Bridge Terrace to Bayfront Section

Project ID

6808 V

Project Description

Replace wooden structures with Self Supporting Steel Structures and upgrade conductor to standard 1272 ACSR.

Project Need

This project is required to address end of life and reliability issues on these lines.

Project Status

Planned

Planned In-Service Date

12/31/25

Previous	2022	2023	2024	2025	2026	Total*
\$0	\$250,000	\$4,000,000	\$7,075,000	\$0	\$0	\$11,325,000

^{*}Total Estimated Amount applied to 2024 Rate Base Calculation

Square D - Hopkins 115kV: Rebuild

Project ID

6808 W

Project Description

Replace wooden H-Frame structures with Self Supporting Steel Structures and restring with 1272 ACSR conductor.

Project Need

This project is required to address end of life and reliability issues on these lines.

Project Status

Planned

Planned In-Service Date

12/31/23

Previous	2022	2023	2024	2025	2026	Total*
\$0	0	\$2,040,000	\$2,664,000	\$0	\$0	\$4,704,000

^{*}Total Estimated Amount applied to 2023 Rate Base Calculation

North-Wagener Jct 46kV: Rebuild North-LNG Tap Section

Project ID

6809 B

Project Description

Replace aging 1/0 Copper conductor with 477 ACSR conductor.

Project Need

This project is required to address end of life and reliability issues on these lines.

Project Status

Planned

Planned In-Service Date

12/31/22

Previous	2022	2023	2024	2025	2026	Total
\$0	\$1,300,000	\$0	\$0	\$0	\$0	\$1,300,000

^{*}Total Estimated Amount applied to the 2022 Rate Base Calculation

Blackville West-Wagener 46kV: Rebuild Wagener Jct-Springfield City Sect.

Project ID

6809 C

Project Description

Rebuilding the 46 kV line as part of System Hardening. Line will be rebuilt SPSC with 1272, 144f OPGW, and a 115 kV insulaton.

Project Need

This project is required to address end of life and reliability issues on these lines.

Project Status

Planned

Planned In-Service Date

12/31/22

Previous	2022	2023	2024	2025	2026	Total
\$134,646	\$8,000,000	\$0	\$0	\$0	\$0	\$8,134,646

^{*}Total Estimated Amount applied to the 2022 Rate Base Calculation

Calhoun County-St Matthews 46kV: Rebuild

Project ID

6809 D

Project Description

Rebuild the Calhoun County - St. Matthews 46kV framed at 115kV. (Approx. 10 miles)

Project Need

This project is required to address end of life and reliability issues on these lines.

Project Status

Planned

Planned In-Service Date

12/31/22

Previous	2022	2023	2024	2025	2026	Total
\$2,294,143	\$2,750,000	\$0	\$0	\$0	\$0	\$5,044,143

^{*}Total Estimated Amount applied to the 2022 Rate Base Calculation

Stevens Creek - Hooks 115kV/LR Plumb Branch 46kV Rebuilds

Project ID

6809 E

Project Description

9.5 miles. Scope includes rebuilding the 115 and 46 kV lines in this corridor SPDC.

Project Need

This project is required to address end of life and reliability issues on these lines.

Project Status

Planned

Planned In-Service Date

12/31/23

Previous	2022	2023	2024	2025	2026	Total
\$9,874	\$100,000	\$10,000,000	\$0	\$0	\$0	\$10,109,874

^{*}Total Estimated Amount applied to the 2023 Rate Base Calculation

Orangeburg #1 - Cameron Jct 46kV Line Rebuild

Project ID

6809 F

Project Description

Replace 7.5 miles of aging poles and conductor.

Project Need

This project is required to address end of life and reliability issues on these lines.

Project Status

Planned

Planned In-Service Date

12/31/24

Previous	2022	2023	2024	2025	2026	Total
\$0	\$0	\$150,000	\$4,600,000	\$0	\$0	\$4,750,000

^{*}Total Estimated Amount applied to the 2024 Rate Base Calculation

Stevens Creek - Hooks 115kV/LR Plumb Branch 46kV

Project ID

6809 G

Project Description

Replace 6.5 miles of aging conductor.

Project Need

This project is required to address end of life and reliability issues on these lines.

Project Status

Planned

Planned In-Service Date

12/31/25

Previous	2022	2023	2024	2025	2026	Total
\$0	\$0	\$0	\$100,000	\$2,000,000	\$0	\$2,100,000

^{*}Total Estimated Amount applied to the 2025 Rate Base Calculation

Cameron - St Matthews 46kV: Rebuild

Project ID

6809 H

Project Description

Replace 8.5 miles of aging poles and conductor.

Project Need

This project is required to address end of life and reliability issues on these lines.

Project Status

Planned

Planned In-Service Date

12/31/26

Previous	2022	2023	2024	2025	2026	Total
\$0	\$0	\$0	\$150,000	\$4,750,000	\$0	\$4,900,000

^{*}Total Estimated Amount applied to the 2026 Rate Base Calculation

Edenwood Sub: #1 & #2 230-115kV Autobanks, Replace with 336MVA

Project ID

6805 G

Project Description

Replace Autobank 1 and 2 at Edenwood Substation.

Project Need

This project is required to address end of life and maintenance issues on these transformers.

Project Status

Planned

Planned In-Service Date

12/25/24

Previous	2022	2023	2024	2025	2026	Total*
\$392	\$60,000	\$2,240,000	\$8,700,00	\$0	\$0	\$11,000,392

^{*}Total Estimated Amount applied to 2024 Rate Base Calculation

Williams St Sub: Replace Sw House & Relays and McMeekin Sub: Add Sw House

Project ID

1060A,L

Project Description

Replace switch house, switch house equipment, and relay panels at Williams Street substation and add Switching House at McMeekin Substation to move relays from plant relay room.

Project Need

This project is required to address end of life and maintenance issues on these transformers.

Project Status

Planned

Planned In-Service Date

12/31/25

Previous	2022	2023	2024	2025	2026	Total*
\$2,706	\$350,000	\$1,700,000	\$1,950,000	\$500,000	\$0	\$4,502,706

^{*}Total Estimated Amount applied to 2025 Rate Base Calculation

Harleyville 115KV Transmission Tap - Construct (1.4 miles)

Project ID

06005 B

Project Description

Extend the 115 kV line from the Blue Circle tap to the Harleyville substation to provide 115 kV service.

Project Need

Load growth.

Project Status

Planned

Planned In-Service Date

12/31/25

Previous	2022	2023	2024	2025	2026	Total*
\$0	\$0	\$250,000	\$2,500,000	\$0	\$0	\$2,750,000

^{*}Total Estimated Amount applied to 2025 Rate Base Calculation

Summerville: Replace and Spare 230-115kV 336MVA Auto Bank

Project ID

05004 P

Project Description

Purchase a spare 230/115kV, 336MVA Autobank for the Southern Region to be stored at Summerville 230kV Sub. Include a pad, AC for heaters, and possibly a pit for oil containment.

Project Need

Spare equipment needs.

Project Status

Planned

Planned In-Service Date

12/31/23

Previous	2022	2023	2024	2025	2026	Total*
\$0	\$784,000	\$2,214,800	\$0	\$0	\$0	\$2,998,800

^{*}Total Estimated Amount applied to 2023 Rate Base Calculation

Canadys-Ritter 115KV-Rebld SPDC 230/115KV 1272 (Approx 18 Miles)

Project ID

06076A

Project Description

Rebuild Canadys-Ritter 115 kV line as SPDC with 230 kV on one side and 115 kV on the other side.

Project Need

This project is needed to improve system performance and to meet NERC TPL and internal DESC Planning Criteria for reliability.

Project Status

Planned

Planned In-Service Date

6/1/2026

Previous	2022	2023	2024	2025	2026	Total*
\$0	\$0	\$0	\$500,000	\$19,500,000	\$20,000,000	\$40,000,000

^{*}Total Estimated Amount applied to 2026 Rate Base Calculation

Yemassee- Ritter 230kV #1 & #2: Construct SPDC with B-1272

Project ID

06359 A

Project Description

Construct Ritter - Yemassee 230kV #1 and #2 SPDC with B1272 ACSR on both sides.

Project Need

This project is needed to improve system performance and to meet NERC TPL and internal DESC Planning Criteria for reliability.

Project Status

Planned

Planned In-Service Date

6/1/2026

Previous	2022	2023	2024	2025	2026	Total*
\$0	\$0	\$100,000	\$4,400,000	\$15,000,000	\$15,000,000	\$34,500,000

^{*}Total Estimated Amount applied to 2026 Rate Base Calculation

Riverport Tap: Construct Tap

Project ID

06367 C

Project Description

Construct Okatie – Riverport 230 kV to feed new Distribution substation.

Project Need

Load growth.

Project Status

Planned

Planned In-Service Date

12/31/24

Previous	2022	2023	2024	2025	2026	Total*
\$0	\$250,000	\$10,000,000	\$10,000,000	\$0	\$0	\$20,250,000

^{*}Total Estimated Amount applied to 2024 Rate Base Calculation

Jasper - Okatie 230 kV #2: Construct

Project ID

06367 E

Project Description

Construct a 230 kV line with 1272 ACSR from the Okatie 230/115kV Substation to the Riverport site. The line is estimated to be 8 miles long.

Project Need

This project is needed to improve system performance and to meet NERC TPL and internal DESC Planning Criteria for reliability.

Project Status

Planned

Planned In-Service Date

12/31/24

Previous	2022	2023	2024	2025	2026	Total*
\$0	\$250,000	\$5,000,000	\$10,500,000	\$0	\$0	\$15,750,000

^{*}Total Estimated Amount applied to 2024 Rate Base Calculation

Wagener 115kV Tap: Construct Tap

Project ID

06371 D

Project Description

Constructing a 115 kV Tap off the Edmund Switching Station- Owens Corning 115 kV Line to feed new Wagener Distribution substation.

Project Need

Load growth.

Project Status

Planned

Planned In-Service Date

12/31/25

Previous	2022	2023	2024	2025	2026	Total*
\$0	\$0	\$0	\$2,850,000	\$3,000,000	\$0	\$5,850,000

^{*}Total Estimated Amount applied to 2025 Rate Base Calculation

Church Creek - Ritter 230kV - Replace 25 Large Angles and Dead Ends

Project ID

06372 A

Project Description

Replace 6.5 miles of aging conductor.

Project Need

Replacing approximately 25 guyed wooden structures due to recent failures in the fiberglass strain insulators along this line. Structures to be changed out are dead ends/large angles.

Project Status

Planned

Planned In-Service Date

12/31/23

Previous	2022	2023	2024	2025	2026	Total
\$35,311	\$4,282,500	\$0	\$0	\$0	\$0	\$4,317,631

^{*}Total Estimated Amount applied to the 2023 Rate Base Calculation

Project 43 of 45

Dominion Energy South Carolina Planned Transmission Projects \$2M and above Total 5 Year Budget

VCS2-Ward 230kV: Rebuild Line

Project ID

06810 F

Project Description

Rebuild 40 miles of 230 kV line.

Project Need

This project is required to address end of life and maintenance issues.

Project Status

Planned

Planned In-Service Date

12/31/26

Previous	2022	2023	2024	2025	2026	Total*
\$0	\$0	\$500,000	\$500,000	\$10,000,000	\$20,000,000	\$31,000,000

^{*}Total Estimated Amount applied to 2026 Rate Base Calculation

Goose Creek Reservoir: Rebuild Transmission Line Crossings

Project ID

06810 G

Project Description

Rebuilding the Williams Goose Creek 230 and 115 kV lines and the Williams - Faber Place 230 kV line across the Goose Creek Reservoir.

Project Need

This project is required to address end of life and maintenance issues.

Project Status

Planned

Planned In-Service Date

12/31/23

Previous	2022	2023	2024	2025	2026	Total*
\$0	\$100,000	\$8,400,000	\$0	\$0	\$0	\$8,500,000

^{*}Total Estimated Amount applied to 2023 Rate Base Calculation

Summerville 115kV Loop: Rebuild

Project ID

06810 H

Project Description

Replacing several wood pole sections on the Summerville 115 kV Loop that have reached the end of life.

Project Need

This project is required to address end of life and maintenance issues.

Project Status

Planned

Planned In-Service Date

12/31/24

Previous	2022	2023	2024	2025	2026	Total*
\$2,602	\$2,250,000	\$4,800,000	\$4,720,000	\$0	\$0	\$11,722,602

^{*}Total Estimated Amount applied to 2024 Rate Base Calculation